

# 2-CHANNEL, ASTRONOMICAL DIGITAL TIME PROGRAMMER ZCM-32, ZCM-32P/U

MANUAL INSTRUCTION



ZAMEL Sp. z o.o.

ul. Zielona 27, 43-200 Pszczyna, Poland  
Tel. +48 (32) 210 46 65, Fax +48 (32) 210 80 04  
www.zamel.com, e-mail: marketing@zamel.pl



## DESCRIPTION

ZCM-32 digital time programmers are used to realize time functions in automation and control systems. Switching on / switching off the device is related to sunset and sunrise (official dawn and dusk). The following information on geographic coordinates of the clock's installation place, current date, and time difference with regard to the universal time (GMT) is used to calculate the time of sunrise and sunset. The system calculates the so-called official time of sunrise and sunset and this is the phase when the upper edge of the Sun touches the horizon. The system is equipped with two independent channels (outputs). The system has the function of a programmable night break and a possibility to change the calculated sunrise/sunset time in the range of ±120 min for each channel. The device casing construction allows the system to be installed on a TH35 rail and additionally the casing can be sealed. The system structure guarantees battery backup of the settings in case of power supply failure.

### CAUTION:

To protect the programmer's battery during storage time, the ZCM-32 series has a 'storage mode' default setting with a minimum current con-

## FEATURES


- control depending on current time in the astronomical cycle,
- night break programme possibility and a change of the calculated sunrise / sunset time independently for channel 1 and 2,
- double modular casing with a protective cover,
- IN control input,
- LCD with backlight,
- mounting on a TH35 rail.

**CAUTION** The device is designed for single-phase installation and must be installed in accordance with standards valid in a particular country. The device should be connected according to the details included in this manual instruction. Installation, connection and control should be carried out by a qualified electrician staff, who act in accordance with the service manual and the device functions. In case of casing dismantling, the guarantee is lost and an electric shock may occur. Before installation make sure the connection cables are not under voltage. Improper transport, storage, and use of the device influence its wrong functioning. It is not advisable to install the device in the following cases: if any device part is missing or the device is damaged or deformed. In case of improper functioning of the device contact the producer.

## TECHNICAL DATA


Input (supply) terminals: A1, A2  
Nominal supply voltage: ZCM-32: 230 V AC~(-15 ÷ +10 %)  
ZCM-32xP/U: 24 ÷ 250V AC, 30 ÷ 300 V DC  
Nominal frequency: 50 / 60 Hz  
Nominal power consumption:  
0,8 W / 1,4 VA – stand-by  
1,8 W / 3,5 VA - channel 1  
and 2 in switched on mode  
Number of channels: 2  
Programme: astronomical (official dawn and dusk)  
Operation modes: automatic, manual  
Summer/winter time change: automatic, manual  
LCD backlight colour: amber  
External input: yes – independent for channel 1 and 2  
Cooperation with external memory:  
ZCM-32: no  
ZCM-32P/U: yes  
Time measuring accuracy: max. ± 1 s / 24 h for 25□  
Clock battery backup: 3 years  
Programme battery backup: 10 years  
Input (release) terminals: IN1, IN1 – for channel 1  
IN2, IN2 – for channel 2  
Output (load) terminals: 11, 12, 14 – channel 1; 21,  
22, 24 – channel 2  
Relay contact parameters: 2 NO / NC 16 A / 250 V AC1 4000 VA  
Number of connection terminals: 12  
Cross-section of connection cables: 0,2 ÷ 2,50 mm²  
Operating temperature range: -20 ÷ +60□  
Operating position: free  
Casing mounting: TH35 rail (acc. to EN 60715)  
Protection degree: IP20 (EN 60529)  
Protection class: II  
Overvoltage category: II  
Pollution degree: 2  
Dimensions: double modular (35 mm) 90 x 35 x 66 mm  
Weight: 0,17 kg  
Reference standard: EN 60730-1; EN 60730-2-7,  
EN 61000-4-2,3,4,5,6,11

## APPEARANCE\*\*



The symbol means selective collecting of electrical and electronic equipment. It is forbidden to put the used equipment together with other waste.

## DESCRIPTION



### Description of elements and messages displayed

Mo Tu We Th Fr Sa Su - days of the week  
On OFF - relay mode  
☉ - automatic mode  
☾ - manual mode  
❄ - winter time  
☀ - summer time  
▶ - external input  
dAY - day  
YEAR - year  
PAUSE - night break setting  
dELAY - time correction setting  
t, m, E - current time setting and summer / winter time change  
dAtE - current date setting

Coord - geographical position setting  
InPut - external input setting  
PEn - external memory operation \*\*  
SAVE - write to external memory \*\*  
rEAd - read from external memory \*\*  
bUSy - external memory usage\*\*  
Err - reading / saving error\*\*  
Sr ISE / S Et - sunrise / sunset time  
Lat It / Lon G - latitude / longitude  
Auto - automatic, USER - user  
On OFF - switched on / switched off


### Description of buttons

- ☉ • in the main window - enter the automatic mode;  
• in other windows – go up one level without saving the entered data;
- ☾ • in the main window – enter the manual mode or change the relay mode if the clock is in the manual mode;  
• in other windows - go up one level without saving the entered data;
- OK • in the main window – enter the main menu;  
• in other windows – enter the submenu or confirm the settings;
- ◀▶ • switching between windows / menu options or increasing /decreasing the pre-set parameters;  
• right cursor (▶) in the main menu – sunrise and sunset time display.

## STORAGE MODE

- The ZCM-32 programmers have a 'storage mode' default setting to protect the battery during storage.
- During battery backup operation, the first programmer activation is realised by means of pressing the (☾) button shortly which causes the storage mode is changed, next it is required to set the date and time.
- During rated voltage operation, the first programmer activation is realised by setting the time and date.
- The programmer can be readjusted to the storage mode by means of carrying out a device reset
- - in order to do it press the (☾) and (☉) buttons simultaneously for a shorter time in the main menu.


## MAIN MENU



Press OK to enter from the main menu to the menu; use cursors (◀▶) to move in the menu. It is possible to enter the main menu again by pressing the (☉) or (☾) button. From the main window you can also enter windows displaying the calculated sunrise/sunset time by pressing the (▶) cursor. Return is automatic after 10 s.

Function	Description
1 PAUSE	NIGHT BREAK SETTING
2 dELAY	SUNRISE / SUNSET TIME CORRECTION SETTING
3 t, m, E	CURRENT TIME SETTING
4 dAtE	CURRENT DATE SETTING
5 t, m, E	SUMMER / WINTER TIME SETTING
6 Coord	GEOGRAPHICAL POSITION AND TIME ZONE SETTING
7 InPut	EXTERNAL INPUT SETTING
8 PEn	EXTERNAL MEMORY SETTING**
9 Sr ISE	CALCULATED SUNRISE TIME
10 S Et	CALCULATED SUNSET TIME


## OPERATION MODE CHANGE (AUTOMATIC, MANUAL)



- 1, 2, 3 Before changing the operation mode select channel (ch-1) or (ch-2) in the main menu by means of the (◀▶) cursor.
- 4 MODE CHANGE INTO MANUAL - if the system is in the main window and the automatic mode (☉) is active, press the (☾) button to change the system into the manual mode with a simultaneous change of the relay mode;
- 5, 6 Subsequent pressing of the (☾) button causes the relay switches to the opposite mode, but the operation mode does not change;
- 7 MODE CHANGE INTO AUTOMATIC - if the system is in the main menu and the manual mode is active, press the (☉) button to change the system into the automatic mode with a simultaneous change of the relay mode;
- 8, 9 Subsequent pressing of the (☉) button causes the relay switches to the opposite mode, but the operation mode does not change;

\* not applicable to ZCM-32  
\*\* applicable to ZCM-32P/U

## NIGHT BREAK SETTING



- 1 PAUSE – setting time correction; press OK to enter the setting view; by means of (◀▶) cursors choose a channel to enter time correction whereas;
- 2 time correction for channel 1 ch-1;
- 3 time correction for channel 2 ch-2.

After choosing the adequate channel by means of cursors (arrow left, arrow right ▶), select the time that must be changed, whereas:


- 4 Correction of dusk time; press OK to enter the edition mode;
- 5 Correction of dawn time; press OK to enter the edition mode;

- 6, 7 Correct the time within the range of -120 ÷ 120 min. By means of (◀▶) cursors, choose an adequate value and confirm the choice with OK;


The time change process for channel 2 (ch-2) is carried out analogically as for channel 1 (ch-1).

**CAUTION!!!**  
The clock will work without a night break, if the start and end time of the night break are the same.

It is possible to exit every sub-menu window in any moment without saving entered settings by pressing the (C) or (M) button.



## TIME CORRECTION SETTING



- 1 dELAY – setting time correction; press OK to enter the setting view; by means of (◀▶) cursors choose a channel to enter time correction whereas;
- 2 time correction for channel 1 ch-1;
- 3 time correction for channel 2 ch-2.


After choosing the adequate channel by means of cursors (arrow left, arrow right ▶), select the time that must be changed, whereas:

- 4 Correction of dusk time; press OK to enter the edition mode;
- 5 Correction of dawn time; press OK to enter the edition mode;
- 6, 7 Correct the time within the range of -120 ÷ 120 min. By means of (◀▶) cursors, choose an adequate value and confirm the choice with OK.

The time change process for channel 2 (ch-2) is carried out analogically as for channel 1 (ch-1).

It is possible to exit every sub-menu window in any moment without saving entered settings by pressing the (C) or (M) button.


## TIME CORRECTION SETTING



- 1 Time correction – setting time correction; press OK to enter the setting view; by means of (◀▶) cursors choose the time to be changed whereas;
- 2 Correction of dusk time; press OK, press OK to enter the edition mode;
- 3 Correction of dawn time; press OK, press OK to enter the edition mode;
- 4 Correct the time within the range of -120 ÷ 120 min. By means of (◀▶) cursors, choose an adequate value and confirm the choice with OK.

It is possible to exit every sub-menu window in any moment without saving entered settings by pressing the (C) or (M) button.


## DATE SETTING



- 1 DATE – setting the current date; press OK to enter;
- 2 YEAR - choose a year by means of (◀▶) cursors, confirm the choice with OK; setting value: 2000+2099;
- 3 MONTH - choose a month by means of (◀▶) cursors, confirm the choice with OK;
- 4 DAY - choose the day of the month by means of (◀▶) cursors; confirm the choice with OK; the system has a safety device to prevent the entry of an incorrect day parameter for a particular month (it includes the leap years) and it automatically calculates the day of the week on the basis of the set date);
- 5 By confirming the above the system changes to a date and current summer/ winter time setting window - if the Auto option is adjusted.


It is possible to exit every sub-menu window in any moment without saving entered settings by pressing the (C) or (M) button.

## WINTER / SUMMER TIME SETTING



- 1 Time correction – the selection of one of two modes where the winter and summer time change will occur: Auto – the change will take place in automatically, on the last Sunday of March at 2.00 (into summer time), and on the last Sunday of October at 3.00 (into winter time), USER – a user chooses between winter/ summer time, press OK to enter;
- 2 MODE SETTING - choose Auto or USER mode by means of (◀▶) cursors, press OK to confirm; after choosing the AUTO mode, the clock automatically sets the time into summer or winter time depending on the adjusted date; after choosing the USER mode you enter another window;
- 3 Choose winter/ summer time by means of cursors where (◀) depicts winter time and (▶) depicts summer time, if the icon changes the system will change the current time by adding or subtracting 1 hour, press OK to confirm;
- 4 After this selection the system enters the window of the summer / winter time change.

## GEOGRAPHICAL POSITION SETTING




- 1 Coord – COORD – setting longitude, latitude and a time zone; press OK to enter the view and setting edition; by means of (◀▶) cursors choose parameters to change, whereas:
- 2 LAT It – latitude;
- 3 LonG – longitude;
- 4 UTC – time zone with reference to UTC;

For window 2 (latitude); press OK to enter the edition:  
5 Choose latitude parameters in the range of 90 South + 90 North by means of (◀▶) cursors; press OK to confirm;  
6 By means of (◀▶) cursors choose latitude minutes (if in step 5 the chosen latitude was 90, this step is omitted).

For window 3 (longitude); press OK to enter the edition:  
7 Choose longitude parameters in the range of 180 West + 180 East by means of (◀▶) cursors; press OK to confirm;  
8 By means of (◀▶) cursors choose longitude minutes (if in step 7 the chosen longitude was 180, this step is omitted).

For window 4 (time zone); press OK to enter the edition:  
9 Choose hour time zone change in the range of -12 + 12; press OK to confirm.


## EXTERNAL INPUT SETTING



It is possible to exit every sub-menu window in any moment without saving entered settings by pressing the (C) or (M) button.

- 1 Input – setting a mode the system should operate in after external input IN release; press OK to enter the edition; choose an appropriate mode for the external input by means of (◀▶) cursors, whereas:
- 2 OFF - the external input function is switched off;
- 3 OFF - manual mode with a permanently switched off relay;
- 4 On - manual mode with a permanently switched on relay;
- 5 - automatic mode, the system realizes the relay switching on / switching off function according to the adjusted programmes;
- 6 Press OK to confirm the selected mode; confirmation allows to enter the external input setting window.

## EXTERNAL MEMORY OPERATION\*\*



The external memory allows to save / read easily the programmes set in the external memory, in this way they can be quickly moved to other programmes. It is very convenient in case we want to programme more ZCM programmes or archive the already set programmes.

- 1 PE\_n – sub-menu for the external memory operation.
- 2 SAVE – programme saving.
- 3 r-ERd – programme reading from the external memory and writing to the programmer's memory.
- 4 BUSY – memory usage status during saving / reading.
- 5 done – correct saving / reading.
- 6 Err – wrong saving / reading.

## GEOGRAPHICAL POSITION OF GREATER TOWNS AND CITIES IN EUROPE


Albania Tirane	41:20:00 °N	019:49:00 °E
Algeria Algiers	36:50:00 °N	003:02:00 °E
Andorra Andorra	42:30:00 °N	001:30:00 °E
Austria Graz	47:05:00 °N	015:22:00 °E
Austria Innsbruck	47:17:00 °N	011:25:00 °E
Austria Leibnitz	46:48:00 °N	015:33:00 °E
Austria Linz	48:19:00 °N	014:18:00 °E
Austria Salzburg	47:54:00 °N	013:03:00 °E
Austria Vienna	48:13:00 °N	016:22:00 °E
Belarus Minsk	53:51:00 °N	027:30:00 °E
Belgium Antwerp	51:13:00 °N	004:25:00 °E
Belgium Brugge	51:12:00 °N	003:14:00 °E
Belgium Brussels	50:50:00 °N	004:21:00 °E
Belgium Liège	50:38:00 °N	005:35:00 °E
Bosnia Sarajevo	43:52:00 °N	018:26:00 °E
Croatia Dubrovnik	42:40:00 °N	018:07:00 °E
Croatia Split	43:31:00 °N	016:28:00 °E
Croatia Zagreb	45:48:00 °N	015:58:00 °E
Cyprus Nicosia	35:10:00 °N	033:22:00 °E
CzechRep Prague	50:05:00 °N	014:25:00 °E
Denmark Aalborg	57:03:00 °N	009:51:00 °E
Denmark Copenhagen	55:43:00 °N	012:34:00 °E
Denmark Odense	55:24:00 °N	010:25:00 °E
Finland Helsinki	60:08:00 °N	025:00:00 °E
Finland Inari	68:54:00 °N	027:05:00 °E
Finland Tampere	61:32:00 °N	023:45:00 °E
Finland Turku	60:27:00 °N	022:15:00 °E
France Bordeaux	44:50:00 °N	000:34:00 °E
France Cherbourg	49:40:00 °N	001:35:00 °E
France Grenoble	45:11:00 °N	005:43:00 °E
France LeChesnay	48:50:00 °N	002:07:00 °E
France LeHavre	49:30:00 °N	000:06:00 °E
France LeMans	48:00:00 °N	000:12:00 °E
France Lyon	45:46:00 °N	004:50:00 °E
France Marseille	43:18:00 °N	005:22:00 °E
France Nancy	48:42:00 °N	006:12:00 °E
France Nantes	47:14:00 °N	001:35:00 °E
France Nice	43:42:00 °N	007:16:00 °E
France Paris	48:52:00 °N	002:20:00 °E
France Rennes	48:06:00 °N	001:40:00 °E
France Strasbourg	48:35:00 °N	007:45:00 °E
France Toulouse	43:42:00 °N	001:28:00 °E
Germany Berlin	52:30:00 °N	013:26:00 °E
Germany Bonn	50:44:00 °N	007:06:00 °E
Germany Dortmund	51:32:00 °N	007:27:00 °E
Germany Dresden	51:03:00 °N	013:45:00 °E
Germany Dusseldorf	51:13:00 °N	006:47:00 °E
Germany Frankfurt	50:06:00 °N	008:41:00 °E
Germany Freiburg	48:00:00 °N	007:52:00 °E
Germany Hamburg	53:33:00 °N	010:00:00 °E
Germany Hannover	52:23:00 °N	009:44:00 °E
Germany Karlsruhe	49:00:00 °N	008:24:00 °E
Germany Kassel	50:19:00 °N	009:30:00 °E
Germany Leipzig	51:20:00 °N	012:20:00 °E
Germany München	48:08:00 °N	011:35:00 °E
Germany Nuremberg	49:27:00 °N	011:05:00 °E
Germany Rostock	54:06:00 °N	012:09:00 °E
Germany STUTTGART	48:47:00 °N	009:12:00 °E
Germany Würzburg	49:48:00 °N	009:57:00 °E
Greece Athens	38:00:00 °N	023:44:00 °E
Greece Thessalonika	40:38:00 °N	022:58:00 °E
Hungary Budapest	47:30:00 °N	019:00:00 °E
Iceland Reykjavik	61:09:00 °N	021:58:00 °E
Ireland Dublin	53:20:00 °N	006:15:00 °E
Ireland Galway	53:16:00 °N	009:03:00 °E
Ireland Limerick	52:40:00 °N	008:38:00 °E
Ireland Waterford	52:15:00 °N	007:06:00 °E
Italy Cagliari	39:13:00 °N	009:08:00 °E
Italy Florence	43:47:00 °N	011:15:00 °E
Italy Milan	45:28:00 °N	009:12:00 °E
Italy Naples	40:50:00 °N	014:15:00 °E
Italy Palermo	38:08:00 °N	013:23:00 °E

Italy Rome	41:53:00 °N	012:30:00 °E
Italy Taranto	40:28:00 °N	017:15:00 °E
Italy Turin	45:04:00 °N	007:40:00 °E
Italy Venice	45:26:00 °N	012:20:00 °E
Latvia Riga	56:53:00 °N	024:08:00 °E
Luxembourg Luxembourg	49:37:00 °N	006:08:00 °E
Macedonia Skopje	42:00:00 °N	021:26:30 °E
Monaco MonteCarlo	43:44:00 °N	007:25:00 °E
Netherlands Amsterdam	52:21:00 °N	004:54:00 °E
Netherlands Apeldoorn	52:13:00 °N	005:57:00 °E
Netherlands Maastricht	50:51:00 °N	005:42:00 °E
Netherlands Nijmegen	51:50:00 °N	005:52:00 °E
Netherlands Rotterdam	51:55:00 °N	004:29:00 °E
Netherlands TheHague	52:05:00 °N	004:16:00 °E
Norway Bergen	60:23:00 °N	005:20:00 °E
Norway Oslo	59:56:00 °N	010:17:00 °E
Norway Stavager	58:58:00 °N	005:45:00 °E
Norway Trondheim	63:36:00 °N	010:23:00 °E
Portugal Lisbon	38:44:00 °N	009:08:00 °E
Portugal Pôrto	41:09:00 °N	008:37:00 °E
Romania Bacau	46:32:00 °N	026:59:00 °E
Romania Bucharest	44:25:00 °N	026:07:00 °E
Russia Irkutsk	52:18:00 °N	104:15:00 °E
Russia Moscow	55:45:00 °N	037:35:00 °E
Russia Murmansk	68:59:00 °N	033:08:00 °E
Russia Novosibirsk	55:04:00 °N	082:51:30 °E
Russia Omsk	55:00:00 °N	073:22:00 °E
Russia Smolensk	54:49:00 °N	032:04:00 °E
Russia StPetersburg	59:55:00 °N	030:25:00 °E
Russia Vladivostok	43:09:00 °N	131:53:00 °E
Russia Volgograd	48:45:00 °N	044:30:00 °E
Slovakia Bratislava	48:10:00 °N	017:10:00 °E
Slovenia Ljubljana	46:40:00 °N	014:30:00 °E
Spain Barcelona	41:25:00 °N	002:10:00 °E
Spain Gibraltar	36:09:00 °N	005:21:00 °E
Spain Madrid	40:25:00 °N	003:43:00 °E
Spain Malaga	36:43:00 °N	004:25:00 °E
Spain Santander	43:28:00 °N	003:48:00 °E
Spain Seville	37:24:00 °N	005:59:00 °E
Spain Valencia	39:29:00 °N	000:24:00 °E
Sweden Goteborg	57:45:00 °N	012:00:00 °E
Sweden Malmö	55:35:00 °N	013:00:00 °E
Sweden Stockholm	59:20:00 °N	018:05:00 °E
Switzerland Basel	47:33:00 °N	007:36:00 °E
Switzerland Geneva	46:13:00 °N	006:09:00 °E
Switzerland Luzern	47:02:00 °N	008:17:30 °E
Switzerland Zürich	47:23:00 °N	008:33:00 °E
Turkey Ankara	39:55:00 °N	032:50:00 °E
Turkey Istanbul	41:02:00 °N	028:59:00 °E
UK Birmingham	52:30:00 °N	001:50:00 °E
UK Brighton	50:50:00 °N	000:10:00 °E
UK Bristol	51:28:00 °N	002:35:00 °E
UK Cardiff	51:30:00 °N	003:12:00 °E
UK Edinburgh	55:56:00 °N	003:14:00 °E
UK Glasgow	55:52:00 °N	004:18:00 °E
UK Leeds	53:50:00 °N	001:34:00 °E
UK Leicester	52:40:00 °N	001:09:00 °E
UK Liverpool	53:24:00 °N	002:58:00 °E
UK London	51:30:00 °N	000:10:00 °E
UK Manchester	53:27:00 °N	002:15:00 °E
UK Middlesborough	54:34:00 °N	001:10:00 °E
UK Newcastle	55:00:00 °N	001:30:00 °E
UK Nottingham	52:58:00 °N	001:10:00 °E
UK Oxford	51:45:00 °N	001:14:00 °E
UK Sheffield	53:24:00 °N	001:27:00 °E
UK Southampton	50:55:00 °N	001:23:00 °E
Ukraine Kiev	50:28:00 °N	030:29:00 °E
Ukraine L'vov	49:50:00 °N	024:00:00 °E
Ukraine Odessa	46:30:00 °N	030:46:00 °E
Ukraine Sevastopol	44:36:00 °N	033:31:00 °E
Yugoslavia Belgrade	44:45:30 °N	022:29:30 °E


## MOUNTING

1. Disconnect power supply by the phase fuse, the circuit-breaker or the switch-disconnector combined to the proper circuit.
2. Check if there is no voltage on the connection cables by means of a special measuring equipment.
3. Install the device on a TH35 rail in the distribution board.
4. Connect the device cables with the terminals in accordance with the installing diagram.
5. Switch on the power supply from the mains.

## INNER DIAGRAM



## CASING DIMENSIONS



## PRODUCT FAMILY

ZCM-32 programmer belongs to the ZCM product family.

### ZCM-xx/U

Power supply voltage:  
ZCM-XX - 230 V AC  
ZCM-XX/U - 24-250 V AC  
30-300 V DC

Programmer type:  
11 - weekly (1 channel)  
12 - weekly (2 channels)  
21 - annual  
31 - astronomical (1 channel)  
32 - astronomical (2 channels)  
XXP - with external memory


Device symbol

## WARRANTY CARD


There is a 24 month guarantee on the product

Salesman stamp and signature, date of sale

## CONNECTION



## CAPACITY



ZCM-32: 230 V AC (-15 + +10 %)  
\*\*ZCM-32P/U: 24 + 250 V AC, 30 + 300 V DC


## ADVANTAGES

**Intelligent calendar** - the system has an in-built calendar, which automatically includes leap years. The above prevents from entering a non-existent date and it also calculates the day of the week with reference to the date and remembers about the summer / winter time change.

**Universal external input** - the system is equipped with an external input that can be used by a user to change the clock work mode without the necessity of interfering in a distribution board, it can be done by means of a remote control button.

**Cooperation with the external memory\*\*** - a user has a possibility to quickly write / read the clock settings to / from the external memory and to transfer them to other programmes.

## MAIN RESET



**CAUTION:** In order to restore factory settings, press the OK button for a while.

1. ZAMEL Sp. z o.o. assures a 24 month guarantee for the product.
2. The manufacturer's guarantee does not cover any of the following actions:
  - a) mechanical damage during transport, loading / unloading or under other circumstances,
  - b) damage caused by incorrect product mounting or misuse,
  - c) damage caused by unauthorised modifications made by the PURCHASER or any third parties to the product or any other devices required for the product functioning,
  - d) damage caused by Act of God or any other incidents independent of the manufacturer - ZAMEL Sp. z o.o.
3. The PURCHASER shall lay any claims in writing in the place of purchase or to ZAMEL Sp. z o.o.
4. ZAMEL Sp. z o.o. is liable for processing any claim according to current Polish legislation.
5. ZAMEL Sp. z o.o. shall process the claim at its own discretion: product repair, replacement or money return.
6. The manufacturer's guarantee is valid in the Republic of Poland.
7. The PURCHASER's statutory rights in any applicable legislation whether against the retailer arising from the purchase contract or otherwise are not affected by this warranty.

\* not applicable to ZCM-32  
\*\* applicable to ZCM-32P/U